



Customer: Central States Diesel Generators STK#2354
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-995-7655

R#: 6182
 Test Date 10-17-2018

Engine Make/ Model: Generac P/N 92460 5.0L 7H22 87800866
 Engine Spec/ Serial: ND722999
 Unit Make/ Model: Caterpillar CD100
 Unit Spec/ Serial: 2036601

Voltage: 120/208
 Amperage: 277
 Kilowatts: 100
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	416.1	416.3	416.6	416.8	417.1	417.2
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	208	208	208	208	208	208
PH2	208	207	207	207	207	208
PH3	207	208	208	208	208	207
Amperage PH1	0	277	277	276	278	0
PH2	0	277	277	278	278	0
PH3	0	277	277	278	277	0
Kilowatts	0	100	100	100	100	0
Oil Pressure	40	38	36	36	36	38
Oil Temperature						
Coolant Temperature	185°F	190°F	190°F	190°F	190°F	185°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14.1	14.1	14.1	14.1	14.1	14.1
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	41°F	41°F	41°F	41°F	41°F	42°F

Technician Signature: _____

Customer Signature: _____