



Customer: Central States Diesel Generators STK#2355  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-995-7655

R#: 6496  
 Test Date 10-22-2018

Engine Make/ Model: Cummins KTA19-G4  
 Engine Spec/ Serial: 37200469  
 Unit Make/ Model: Cummins DFED-5001414  
 Unit Spec/ Serial: J010292328

Voltage: 277/480  
 Amperage: 601  
 Kilowatts: 500  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	339.6	339.8	340.1	340.3	340.6	340.7
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	481	480	480	481	480	481
PH2	480	481	481	480	481	480
PH3	481	482	481	481	481	481
Amperage PH1	0	600	602	601	601	0
PH2	0	601	602	601	600	0
PH3	0	601	601	602	602	0
Kilowatts	0	500	500	500	500	0
Oil Pressure	75	71	71	70	70	72
Oil Temperature						
Coolant Temperature	180°F	181°F	181°F	182°F	182°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28	28	28	28	28	28
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	51°F	51°F	52°F	52°F	52°F	52°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_