



Customer: Central States Diesel Generators STK#2356
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-995-7655

R#: 6353
 Test Date 11-16-2018

Engine Make/ Model: Cummins KTA38-G2
 Engine Spec/ Serial: 33124788
 Unit Make/ Model: Cummins 800DFJB
 Unit Spec/ Serial: G930514691 Spec. 63509J

Voltage: 277/480
 Amperage: 1203
 Kilowatts: 800
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	1091	1091.2	1091.5	1091.8	1092	1092.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	481	480	480	480
PH2	482	481	481	481	482	482
PH3	480	480	480	480	480	480
Amperage PH1	0	962	961	962	963	0
PH2	0	963	962	963	962	0
PH3	0	963	963	962	961	0
Kilowatts	0	800	800	800	800	0
Oil Pressure	95	80	80	80	80	85
Oil Temperature						
Coolant Temperature	180°F	185°F	185°F	185°F	185°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28.1	28.1	28.1	28.1	28.1	28.1
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	36°F	36°F	36°F	36°F	36°F	37°F

Technician Signature: _____

Customer Signature: _____