



Customer: Central States Diesel Generators STK#2357  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-995-7655

R#: TBA  
 Test Date 10-18-2018

Engine Make/ Model: John Deere 6068HF285  
 Engine Spec/ Serial: PE6068L007861  
 Unit Make/ Model: Katolight D125FGJ4T3  
 Unit Spec/ Serial: 140185-0307

Voltage: 120/240 1PH  
 Amperage: 625  
 Kilowatts: 150  
 Power Factor 1

|                      | 5 Min. | 15 Min. | 30 Min. | 45 Min. | 1 Hour | Cool Down |
|----------------------|--------|---------|---------|---------|--------|-----------|
| Eng Hours            | 78.4   | 78.6    | 78.9    | 79.1    | 79.4   | 79.5      |
| Hertz/Cycles         | 60     | 60      | 60      | 60      | 60     | 60        |
| Voltage PH1 to PH2   | 240    | 240     | 240     | 240     | 240    | 240       |
| PH1 to N             | 120    | 120     | 120     | 120     | 120    | 120       |
| PH2 to N             | 120    | 120     | 120     | 120     | 120    | 120       |
| Amperage PH1         | 0      | 625     | 626     | 626     | 625    | 0         |
| PH2                  | 0      | 625     | 625     | 626     | 625    | 0         |
| PH3                  | n/a    | n/a     | n/a     | n/a     | n/a    | n/a       |
| Kilowatts            | 0      | 150     | 150     | 150     | 150    | 0         |
| Oil Pressure         | 44     | 40      | 40      | 40      | 40     | 42        |
| Oil Temperature      |        |         |         |         |        |           |
| Coolant Temperature  | 180°F  | 185°F   | 185°F   | 185°F   | 185°F  | 183°F     |
| Man Vac./Press. L/B  |        |         |         |         |        |           |
| Man Vac./Press. R/B  |        |         |         |         |        |           |
| L/B Exhaust Temp     |        |         |         |         |        |           |
| R/B Exhaust Temp     |        |         |         |         |        |           |
| Exhaust Temperature  |        |         |         |         |        |           |
| DC Voltage           | 14.1   | 14.1    | 14.1    | 14.1    | 14.1   | 14.1      |
| Natural Gas Pressure |        |         |         |         |        |           |
| Diesel Fuel Level    |        |         |         |         |        |           |
| Room Temperature     |        |         |         |         |        |           |
| Ambient Temperature  | 52°F   | 52°F    | 52°F    | 53°F    | 53°F   | 53°F      |

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_