



Customer: Central States Diesel Generators STK#2358
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-995-7655

R#: TBA
 Test Date 10-18-2018

Engine Make/ Model: John Deere 6068TF250
 Engine Spec/ Serial: PE6068T139756
 Unit Make/ Model: Katolight D125FGJ4
 Unit Spec/ Serial: LM240261 76852

Voltage: 120/240 1PH
 Amperage: 521
 Kilowatts: 125
 Power Factor 1

| | 5 Min. | 15 Min. | 30 Min. | 45 Min. | 1 Hour | Cool Down |
|----------------------|--------|---------|---------|---------|--------|-----------|
| Eng Hours | 194.5 | 194.7 | 195 | 195.2 | 195.5 | 195.6 |
| Hertz/Cycles | 60 | 60 | 60 | 60 | 60 | 60 |
| Voltage PH1 to PH2 | 240 | 240 | 240 | 240 | 240 | 240 |
| PH1 to N | 120 | 120 | 120 | 120 | 120 | 120 |
| PH2 to N | 120 | 120 | 120 | 120 | 120 | 120 |
| Amperage PH1 | 0 | 521 | 520 | 521 | 521 | 0 |
| PH2 | 0 | 520 | 522 | 521 | 521 | 0 |
| PH3 | n/a | n/a | n/a | n/a | n/a | n/a |
| Kilowatts | 0 | 125 | 125 | 125 | 125 | 0 |
| Oil Pressure | 46 | 45 | 45 | 45 | 45 | 45 |
| Oil Temperature | | | | | | |
| Coolant Temperature | 185°F | 190°F | 190°F | 190°F | 190°F | 185°F |
| Man Vac./Press. L/B | | | | | | |
| Man Vac./Press. R/B | | | | | | |
| L/B Exhaust Temp | | | | | | |
| R/B Exhaust Temp | | | | | | |
| Exhaust Temperature | | | | | | |
| DC Voltage | 14.1 | 14.1 | 14.1 | 14.1 | 14.1 | 14.1 |
| Natural Gas Pressure | | | | | | |
| Diesel Fuel Level | | | | | | |
| Room Temperature | | | | | | |
| Ambient Temperature | 53°F | 53°F | 53°F | 53°F | 53°F | 54°F |

Technician Signature: Randy Pool

Customer Signature: _____