



Customer: Central States Diesel Generators STK#2361
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 6313
 Test Date 11-12-2018

Engine Make/ Model: Cummins QST30-G3
 Engine Spec/ Serial: S/N-37202556 Family-D57300IGX03
 Unit Make/ Model: Cummins DFHC-5553509
 Unit Spec/ Serial: Spec.-D S/N-C020341800

Voltage: 277/480
 Amperage: 1354
 Kilowatts: 900
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	1241.6	1241.8	1242.1	1242.3	1242.6	1242.7
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	484	485	485	484	484	485
PH2	485	485	484	485	484	486
PH3	483	484	484	484	485	483
Amperage PH1	0	1077	1078	1078	1077	0
PH2	0	1078	1077	1075	1076	0
PH3	0	1079	1076	1077	1076	0
Kilowatts	0	904	902	902	902	0
Oil Pressure	60	56	55	55	55	57
Oil Temperature	190°F	200°F	200°F	200°F	200°F	195°F
Coolant Temperature	170°F	172°F	172°F	172°F	173°F	170°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.3	27.3	27.3	27.3	27.3	27.3
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	27°F	27°F	27°F	27°F	27°F	27°F

Technician Signature: Randy Pool

Customer Signature: _____