



Customer: Central States Diesel Generators STK#2362
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-995-7655

R#: 6220
 Test Date 10-23-2018

Engine Make/ Model: Cummins NTTA855G32
 Engine Spec/ Serial: 11351527
 Unit Make/ Model: Cummins 502FDR7044JJ W
 Unit Spec/ Serial: SJ 19-52324-8/1

Voltage: 277/480
 Amperage: 421
 Kilowatts: 350
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	2011.5	2011.7	2012	2012.2	2012.5	2012.6
Hertz/Cycles	60.1	60.1	60.1	60.1	60.1	60.1
Voltage PH1	483	482	483	483	482	483
PH2	484	483	483	483	483	484
PH3	483	482	482	483	482	483
Amperage PH1	0	419	420	419	419	0
PH2	0	419	420	419	419	0
PH3	0	420	419	418	419	0
Kilowatts	0	350	350	350	350	0
Oil Pressure	65	60	60	60	60	62
Oil Temperature						
Coolant Temperature	180°F	180°F	180°F	180°F	180°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14.1	14.1	14.1	14.1	14.1	14.1
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	52°F	52°F	52°F	52°F	53°F	53°F

Technician Signature: Randy Pool

Customer Signature: _____