



Customer: Central States Diesel Generators STK#2363  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-955-7655

R#: 6251  
 Test Date 11-5-2018

Engine Make/ Model: Cummins KTA19-G4  
 Engine Spec/ Serial: 37192292  
 Unit Make/ Model: Cummins DFED-4478217  
 Unit Spec/ Serial: Spec.-E C000084269

Voltage: 277/480  
 Amperage: 601  
 Kilowatts: 500  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	183.3	183.5	183.8	184	184.3	184.4
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	485	485	485	485	485	485
PH2	485	485	485	485	485	486
PH3	485	484	484	484	484	483
Amperage PH1	0	596	596	597	595	0
PH2	0	596	597	596	597	0
PH3	0	597	596	597	596	0
Kilowatts	0	500	500	500	500	0
Oil Pressure	80	68	36	36	36	38
Oil Temperature	190°F	203°F	204°F	203°F	203°F	195°F
Coolant Temperature	180°F	181°F	180°F	181°F	180°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28	28	28	28	28	28
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	47°F	47°F	47°F	47°F	47°F	48°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_