



Customer: Central States Diesel Generators STK#2364
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-995-7655

R#: 6250
 Test Date 11-5-2018

Engine Make/ Model: Cummins KTA19-G4
 Engine Spec/ Serial: 37192149
 Unit Make/ Model: Cummins DFED-4478217
 Unit Spec/ Serial: Spec.-E S/N-C000084270

Voltage: 277/480
 Amperage: 601
 Kilowatts: 500
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	228.3	228.5	228.8	229	229.3	229.4
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	485	485	485	485	485	485
PH2	486	486	486	486	486	486
PH3	483	484	483	483	484	483
Amperage PH1	0	597	596	597	595	0
PH2	0	596	597	596	597	0
PH3	0	597	596	597	596	0
Kilowatts	0	501	500	500	500	0
Oil Pressure	74	68	36	36	36	38
Oil Temperature	190°F	203°F	204°F	203°F	203°F	195°F
Coolant Temperature	180°F	181°F	180°F	181°F	180°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28	28	28	28	28	28
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	45°F	45°F	46°F	46°F	46°F	46°F

Technician Signature: Randy Pool

Customer Signature: _____