



Customer: Central States Diesel Generators STK#2366
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 9575
 Test Date 7-20-20

Engine Make/ Model: Cummins QSM11-G4 NR3
 Engine Spec/ Serial: 35208458
 Unit Make/ Model: Cummins DQHAB-5935324
 Unit Spec/ Serial: I070111624 Spec. A

Voltage: 277/480
 Amperage: 361
 Kilowatts: 300
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	414.6	414.8	415.1	415.3	415.6	415.7
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	481	480	480	480	480
PH2	480	480	480	480	480	480
PH3	480	481	481	480	480	480
Amperage PH1	0	361	361	360	360	0
PH2	0	360	361	360	360	0
PH3	0	361	361	360	361	0
Kilowatts	0	300	300	300	300	0
Oil Pressure	44	41	38	37	37	39
Oil Temperature						
Coolant Temperature	180°F	187°F	187°F	187°F	187°F	182°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28.1	28.1	28.1	28.1	28.1	28.1
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	80°F	80°F	80°F	80°F	81°F	81°F

Technician Signature: Randy Pool

Customer Signature: _____