



Customer: Central States Diesel Generators STK#2367
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-995-7655

R#: 6469
 Test Date 12-13-2018

Engine Make/ Model: Caterpillar 3412
 Engine Spec/ Serial: 81Z17963
 Unit Make/ Model: Caterpillar 3412 SR-4 5N-8670
 Unit Spec/ Serial: 81Z17963 6FA10914

Voltage: 277/480
 Amperage: 752
 Kilowatts: 500
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	882	882	882	883	883	883
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	481	481	481	480	480
PH2	481	481	481	481	482	481
PH3	480	480	482	482	481	480
Amperage PH1	0	600	601	600	602	0
PH2	0	602	601	601	600	0
PH3	0	601	601	600	601	0
Kilowatts	0	500	500	500	500	0
Oil Pressure	97	74	72	72	72	77
Oil Temperature						
Coolant Temperature	180°F	185°F	185°F	185°F	185°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	25	25	25	25	25	25
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	36°F	36°F	36°F	36°F	36°F	36°F

Technician Signature: _____

Customer Signature: _____