



Customer: Central States Diesel Generators STK#2371

Address: 2001 S Prairie Ave.

City/ State/ Zip Waukesha, WI 53189

Contact: Patrick Paden

Phone: 262-995-7655

R#: 6634

Test Date 1-24-2019

Engine Make/ Model: Cummins QST30-G1

Engine Spec/ Serial: 37188953

Voltage: 277/480

Amperage: 903

Unit Make/ Model: Cummins 750DFHA

Kilowatts: 750

Unit Spec/ Serial: H990970663

Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	2987	2987.3	2987.5	2987.8	2988	2988.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	487	486	487	487	487	487
PH2	487	486	487	487	487	487
PH3	486	486	485	486	486	486
Amperage PH1	0	892	890	892	891	0
PH2	0	893	892	891	890	0
PH3	0	890	891	890	892	0
Kilowatts	0	750	750	750	750	0
Oil Pressure	62	54	53	52	52	53
Oil Temperature						
Coolant Temperature	170°F	175°F	175°F	175°F	175°F	170°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27	27	27	27	27	27
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	24°F	24°F	24°F	24°F	24°F	24°F

Technician Signature: Randy Pool

Customer Signature: _____