



Customer: Central States Diesel Generators STK#2373
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 6315
 Test Date 11-12-2018

Engine Make/ Model: Cummins NTA855G
 Engine Spec/ Serial: 30111848
 Unit Make/ Model: ONAN 250.0DFM-17R/24788M
 Unit Spec/ Serial: D820615961

Voltage: 277/480
 Amperage: 376
 Kilowatts: 250
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	861.3	861.5	861.8	862	862.3	862.4
Hertz/Cycles	59.8	59.7	59.8	59.8	59.7	59.8
Voltage PH1	482	483	483	482	483	482
PH2	484	484	483	483	484	484
PH3	484	484	483	484	483	484
Amperage PH1	0	300	298	299	299	0
PH2	0	299	300	298	298	0
PH3	0	298	298	299	299	0
Kilowatts	0	250	250	250	250	0
Oil Pressure	70	66	65	65	65	65
Oil Temperature	180°F	205°F	205°F	205°F	205°F	200°F
Coolant Temperature	180°F	195°F	195°F	195°F	195°F	190°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.5	27.5	27.5	27.5	27.5	27.5
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	28°F	28°F	28°F	28°F	28°F	29°F

Technician Signature: _____

Customer Signature: _____