



Customer: Central States Diesel Generators STK#2375  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-995-7655

R#: 6514  
 Test Date 12-21-2018

Engine Make/ Model: Cummins QSX15-G9  
 Engine Spec/ Serial: 79121782  
 Unit Make/ Model: Cummins 500DFEK-5582  
 Unit Spec/ Serial: I050834932 Spec. E

Voltage: 277/480  
 Amperage: 602  
 Kilowatts: 500  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	470.2	470.5	470.7	471	471.2	471.3
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	483	482	483	483	482	483
PH2	485	484	485	484	484	485
PH3	481	480	481	481	480	481
Amperage PH1	0	601	600	602	601	0
PH2	0	598	598	598	598	0
PH3	0	600	600	600	600	0
Kilowatts	0	500	501	501	500	0
Oil Pressure	45	41	40	40	40	41
Oil Temperature	200°F	225°F	225°F	225°F	225°F	222°F
Coolant Temperature	175°F	178°F	178°F	178°F	178°F	177°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.1	27.1	27.1	27.1	27.1	27.1
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	31°F	31°F	32°F	32°F	32°F	32°F

Technician Signature: \_\_\_\_\_

Customer Signature: \_\_\_\_\_