



Customer: Central States Diesel Generators STK#2376  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-995-7655

R#: 6502  
 Test Date 1-3-2019

Engine Make/ Model: Cummins NT855G6  
 Engine Spec/ Serial: 25295322  
 Unit Make/ Model: Triton  
 Unit Spec/ Serial: NO TAG

Voltage: 277/480  
 Amperage: 331  
 Kilowatts: 275  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	94.3	94.6	94.8	95.1	95.3	95.4
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	481	481	480	481	480
PH2	481	481	480	480	481	481
PH3	480	480	481	480	481	480
Amperage PH1	0	330	330	329	331	0
PH2	0	331	330	331	331	0
PH3	0	330	331	331	330	0
Kilowatts	0	275	275	274	275	0
Oil Pressure	62	60	58	58	58	59
Oil Temperature						
Coolant Temperature	120°F	125°F	125°F	125°F	125°F	120°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	25	25	25	25	25	25
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	24°F	24°F	24°F	24°F	24°F	24°F

Technician Signature: \_\_\_\_\_

Customer Signature: \_\_\_\_\_