



Customer: Central States Diesel Generators STK#2377  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-995-7655

R#: 6500  
 Test Date 12-18-2018

Engine Make/ Model: Cummins NTTA855G2  
 Engine Spec/ Serial: 11426869  
 Unit Make/ Model: Katolight D350FRZ4  
 Unit Spec/ Serial: TL3415366

Voltage: 277/480  
 Amperage: 526  
 Kilowatts: 350  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	1683.2	1683.5	1683.7	1684	1684.2	1684.3
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	481	481	481	480	480	481
PH2	480	480	480	480	480	480
PH3	480	481	480	480	480	480
Amperage PH1	0	420	421	420	421	0
PH2	0	421	420	421	421	0
PH3	0	421	421	420	421	0
Kilowatts	0	350	350	349	350	0
Oil Pressure	65	59	58	57	57	60
Oil Temperature						
Coolant Temperature	180°F	180°F	180°F	180°F	180°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28	28	28	28	28	28
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	41°F	42°F	42°F	42°F	43°F	43°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_