



Customer: Central States Diesel Generators STK#2378  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-995-7655

R#: 6501  
 Test Date 12-18-2018

Engine Make/ Model: Perkins 2006-TAG  
 Engine Spec/ Serial: 8C26879U78892S  
 Unit Make/ Model: Katolight D300FRP4  
 Unit Spec/ Serial: UK3522419 L-36645

Voltage: 277/480  
 Amperage: 451  
 Kilowatts: 300  
 Power Factor 0.8

|                      | 5 Min.     | 15 Min. | 30 Min. | 45 Min. | 1 Hour | Cool Down |
|----------------------|------------|---------|---------|---------|--------|-----------|
| Eng Hours            | 424.3      | 424.5   | 424.8   | 425     | 425.3  | 425.4     |
| Hertz/Cycles         | 60         | 60      | 60      | 60      | 60     | 60        |
| Voltage PH1          | 480        | 480     | 480     | 479     | 480    | 480       |
| PH2                  | 479        | 480     | 479     | 479     | 480    | 479       |
| PH3                  | 480        | 479     | 479     | 480     | 479    | 480       |
| Amperage PH1         | 0          | 362     | 361     | 361     | 362    | 0         |
| PH2                  | 0          | 361     | 361     | 362     | 361    | 0         |
| PH3                  | 0          | 362     | 361     | 361     | 362    | 0         |
| Kilowatts            | 0          | 300     | 299     | 300     | 300    | 0         |
| Oil Pressure         | 97         | 77      | 65      | 65      | 65     | 70        |
| Oil Temperature      |            |         |         |         |        |           |
| Coolant Temperature  | 180°F      | 180°F   | 180°F   | 180°F   | 180°F  | 180°F     |
| Man Vac./Press. L/B  |            |         |         |         |        |           |
| Man Vac./Press. R/B  |            |         |         |         |        |           |
| L/B Exhaust Temp     |            |         |         |         |        |           |
| R/B Exhaust Temp     |            |         |         |         |        |           |
| Exhaust Temperature  |            |         |         |         |        |           |
| DC Voltage           | 62-995-765 | 26      | 26      | 26      | 26     | 26        |
| Natural Gas Pressure |            |         |         |         |        |           |
| Diesel Fuel Level    |            |         |         |         |        |           |
| Room Temperature     |            |         |         |         |        |           |
| Ambient Temperature  | 40°F       | 41°F    | 41°F    | 41°F    | 41°F   | 41°F      |

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_