



Customer: Central States Diesel Generators STK#2381
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 6745
 Test Date 6-10-2019

Engine Make/ Model: Caterpillar 3512 D1
 Engine Spec/ Serial: 24Z01193
 Unit Make/ Model: Caterpillar 3512 D1
 Unit Spec/ Serial: 24Z01193

Voltage: 277/480
 Amperage: 1203
 Kilowatts: 800
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	1777	1777	1777	1778	1778	1778
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	480	480	480	480
PH2	481	481	481	481	481	481
PH3	481	480	481	480	480	481
Amperage PH1	0	964	963	962	963	0
PH2	0	962	962	962	960	0
PH3	0	963	961	963	964	0
Kilowatts	0	800	800	800	800	0
Oil Pressure	75	67	66	66	65	68
Oil Temperature						
Coolant Temperature	170°F	170°F	170°F	170°F	170°F	170°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	25	25	25	25	25	25
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	59°F	59°F	60°F	60°F	60°F	61°F

Technician Signature: Randy Pool

Customer Signature: _____