



Customer: Central States Diesel Generators STK#2382
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 6563
 Test Date 1-9-2019

Engine Make/ Model: MTU 10V1600G80S
 Engine Spec/ Serial: 16601001467
 Unit Make/ Model: MTU DS00500D6SRAH1484
 Unit Spec/ Serial: 346870-1-1-0512

Voltage: 277/480
 Amperage: 601
 Kilowatts: 500
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	2341.4	2341.6	2341.9	2342.1	2342.4	2342.5
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	481	482	481	481	482	481
PH2	483	482	483	482	482	483
PH3	480	480	481	480	481	480
Amperage PH1	0	600	601	600	601	0
PH2	0	601	600	602	601	0
PH3	0	602	601	600	601	0
Kilowatts	0	500	501	500	501	0
Oil Pressure	90	88	88	87	87	88
Oil Temperature						
Coolant Temperature	160°F	170°F	170°F	170°F	170°F	165°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.7	27.7	27.7	27.7	27.7	27.7
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	17°F	17°F	17°F	17°F	17°F	18°F

Technician Signature: Randy Pool

Customer Signature: _____