



Customer: Central States Diesel Generators STK#2383
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 6568
 Test Date 1-24-2019

Engine Make/ Model: Perkins T4.236
 Engine Spec/ Serial: 49856
 Unit Make/ Model: Katolight D60F*P4
 Unit Spec/ Serial: LM180046 F-41965

Voltage: 277/480 (Multi-Select)
 Amperage: 72
 Kilowatts: 60
 Power Factor 0.8

| | 5 Min. | 15 Min. | 30 Min. | 45 Min. | 1 Hour | Cool Down |
|----------------------|--------|---------|---------|---------|--------|-----------|
| Eng Hours | 3312.3 | 3312.5 | 3312.8 | 3313 | 3313.3 | 3313.4 |
| Hertz/Cycles | 60 | 60 | 60 | 60 | 60 | 60 |
| Voltage PH1 | 474 | 475 | 474 | 474 | 474 | 474 |
| PH2 | 475 | 475 | 474 | 475 | 475 | 475 |
| PH3 | 474 | 474 | 475 | 474 | 475 | 474 |
| Amperage PH1 | 0 | 74 | 73 | 74 | 73 | 0 |
| PH2 | 0 | 73 | 74 | 73 | 73 | 0 |
| PH3 | 0 | 74 | 73 | 74 | 74 | 0 |
| Kilowatts | 0 | 60 | 60 | 60 | 60 | 0 |
| Oil Pressure | 80 | 78 | 76 | 76 | 76 | 77 |
| Oil Temperature | | | | | | |
| Coolant Temperature | 170°F | 175°F | 175°F | 175°F | 175°F | 170°F |
| Man Vac./Press. L/B | | | | | | |
| Man Vac./Press. R/B | | | | | | |
| L/B Exhaust Temp | | | | | | |
| R/B Exhaust Temp | | | | | | |
| Exhaust Temperature | | | | | | |
| DC Voltage | 14.1 | 14.1 | 14.1 | 14.1 | 14.1 | 14.1 |
| Natural Gas Pressure | | | | | | |
| Diesel Fuel Level | | | | | | |
| Room Temperature | | | | | | |
| Ambient Temperature | 8°F | 8°F | 8°F | 8°F | 8°F | 8°F |

Technician Signature: Randy Pool

Customer Signature: _____