



Customer: Central States Diesel Generators STK#2385
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 6945
 Test Date 3-22-2019

Engine Make/ Model: John Deere 6068HF285
 Engine Spec/ Serial: PE6068L117014
 Unit Make/ Model: Doosan G185
 Unit Spec/ Serial: 423256UCVC28

Voltage: 139/240
 Amperage: 440
 Kilowatts: 146
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	1327	1327.2	1327.5	1327.7	1328	1328.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	241	241	241	241	241	241
PH2	240	241	240	240	240	240
PH3	241	242	241	241	241	241
Amperage PH1	0	351	349	350	349	0
PH2	0	350	350	351	350	0
PH3	0	350	350	351	350	0
Kilowatts	0	146	146	146	146	0
Oil Pressure	OK	OK	OK	OK	OK	OK
Oil Temperature						
Coolant Temperature	OK	OK	OK	OK	OK	OK
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14.2	14.2	14.2	14.2	14.2	14.2
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	40°F	40°F	40°F	40°F	40°F	40°F

Technician Signature: _____

Customer Signature: _____