



Customer: Central States Diesel Generators STK#2386
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 6946
 Test Date 3-22-2019

Engine Make/ Model: John Deere 6068HF285
 Engine Spec/ Serial: PE6068L117012
 Unit Make/ Model: Doosan G185
 Unit Spec/ Serial: 423791UCVC28

Voltage: 139/240
 Amperage: 440
 Kilowatts: 146
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	11141.4	11141.6	11141.9	11142.1	11142.4	11142.5
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	242	241	242	241	242	242
PH2	239	241	240	241	241	239
PH3	240	241	240	240	240	240
Amperage PH1	0	350	352	351	350	0
PH2	0	349	349	351	351	0
PH3	0	350	350	349	350	0
Kilowatts	0	146	146	146	146	0
Oil Pressure	OK	OK	OK	OK	OK	OK
Oil Temperature						
Coolant Temperature	OK	OK	OK	OK	OK	OK
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14.1	14.1	14.1	14.1	14.1	14.1
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	41°F	41°F	41°F	41°F	41°F	41°F

Technician Signature: _____

Customer Signature: _____