



Customer: Central States Diesel Generators STK#2392
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 7115
 Test Date 4-16-2019

Engine Make/ Model: Cummins QSL9-G3 NR3
 Engine Spec/ Serial: 73262160
 Unit Make/ Model: Doosan G290
 Unit Spec/ Serial: 430395UIVE26

Voltage: 277/480
 Amperage: 384
 Kilowatts: 255
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	5105.5	5105.8	5106	5106.2	5106.5	5106.6
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	479	478	477	478	478	479
PH2	479	477	478	477	477	479
PH3	479	478	478	479	478	479
Amperage PH1	0	309	310	308	309	0
PH2	0	309	309	309	310	0
PH3	0	309	308	308	308	0
Kilowatts	0	255	255	255	255	0
Oil Pressure	OK	OK	OK	OK	OK	OK
Oil Temperature						
Coolant Temperature	OK	OK	OK	OK	OK	OK
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.9	27.9	27.9	27.9	27.9	27.9
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	55°F	55°F	55°F	56°F	56°F	56°F

Technician Signature: Randy Pool

Customer Signature: _____