



Customer: Central States Diesel Generators STK#2393
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 7116
 Test Date 4-16-2019

Engine Make/ Model: Cummins QSL9-G3 NR3
 Engine Spec/ Serial: 73262159
 Unit Make/ Model: Doosan G290
 Unit Spec/ Serial: 430394UIVE26

Voltage: 277/480
 Amperage: 384
 Kilowatts: 255
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	8660.2	8660.5	8660.7	8661	8661.2	8661.3
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	479	479	479	478	479	479
PH2	478	479	479	478	479	478
PH3	479	479	479	479	479	479
Amperage PH1	0	308	308	307	307	0
PH2	0	307	306	307	308	0
PH3	0	308	308	309	308	0
Kilowatts	0	255	255	255	255	0
Oil Pressure	OK	OK	OK	OK	OK	OK
Oil Temperature						
Coolant Temperature	OK	OK	OK	OK	OK	OK
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.8	27.8	27.8	27.8	27.8	27.8
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	53°F	53°F	53°F	54°F	54°F	54°F

S

Technician Signature: Randy Pool

Customer Signature: _____