



Customer: Central States Diesel Generators STK#2394
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-995-7655

R#: 6773
 Test Date 2-25-2019

Engine Make/ Model: Cummins QSX15-G9
 Engine Spec/ Serial: 79500795
 Unit Make/ Model: Doosan G450
 Unit Spec/ Serial: 43095001VE28

Voltage: 277/480
 Amperage: 549
 Kilowatts: 365
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	6685	6685.3	6685.5	6685.8	6686	6686.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	481	480	481	481	481	481
PH2	481	481	481	480	481	481
PH3	479	480	479	479	480	479
Amperage PH1	0	440	439	440	439	0
PH2	0	438	440	439	439	0
PH3	0	439	440	441	440	0
Kilowatts	0	365	365	365	365	0
Oil Pressure	OK	OK	OK	OK	OK	OK
Oil Temperature						
Coolant Temperature	OK	OK	OK	OK	OK	OK
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28	28	28	28	28	28
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	7°F	7°F	8°F	8°F	8°F	8°F

Technician Signature: Randy Pool

Customer Signature: _____