



Customer: Central States Diesel Generators STK#2395

Address: 2001 S Prairie Ave.

City/ State/ Zip Waukesha, WI 53189

Contact: Patrick Paden

Phone: 262-955-7655

R#: 6577

Test Date 1-11-2019

Engine Make/ Model: Caterpillar 3412

Engine Spec/ Serial: 1EZ01402

Unit Make/ Model: Caterpillar 3412

Unit Spec/ Serial: SR4 AFK00143

Voltage: 277/480

Amperage: 902

Kilowatts: 750

Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	1090	1090	1090	1091	1091	1091
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	485	486	486	485	486	485
PH2	486	486	485	486	486	486
PH3	487	486	486	487	486	486
Amperage PH1	0	891	893	892	893	0
PH2	0	893	892	893	890	0
PH3	0	892	892	891	893	0
Kilowatts	0	750	750	750	750	0
Oil Pressure	84	68	60	59	59	62
Oil Temperature						
Coolant Temperature	180°F	185°F	185°F	185°F	185°F	184°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27	27	27	27	27	27
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	21°F	21°F	21°F	21°F	21°F	22°F

Technician Signature: Randy Pool

Customer Signature: _____