



Customer: Central States Diesel Generators STK#2396

Address: 2001 S Prairie Ave.

City/ State/ Zip Waukesha, WI 53189

Contact: Patrick Paden

Phone: 262-995-7655

R#: 6686

Test Date 2-4-2019

Engine Make/ Model: Cummins NTA-855-G2

Engine Spec/ Serial: 30363628

Voltage: 120/208

Amperage: 833

Unit Make/ Model: Cummins DFCB-3382955

Kilowatts: 300

Unit Spec/ Serial: L990028588

Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	130.6	130.8	131.1	131.3	131.6	131.7
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	210	210	209	210	209	210
PH2	209	209	209	208	209	209
PH3	209	208	209	209	209	209
Amperage PH1	0	831	830	829	830	0
PH2	0	829	829	828	829	0
PH3	0	832	830	829	829	0
Kilowatts	0	300	300	300	300	0
Oil Pressure	55	51	50	50	50	51
Oil Temperature	201°F	213°F	212°F	213°F	213°F	203°F
Coolant Temperature	180°F	180°F	180°F	180°F	180°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.7	27.7	27.7	27.7	27.7	27.7
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	46°F	46°F	46°F	46°F	47°F	47°F

Technician Signature: _____

Customer Signature: _____