



Customer: Central States Diesel Generators STK#2401
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-995-7655

R#: 6716
 Test Date 2-19-2019

Engine Make/ Model: Cummins KTA-50-G1
 Engine Spec/ Serial: 33113335
 Unit Make/ Model: Cummins 1000R0Z71
 Unit Spec/ Serial: Spec. 116513-71 S/N230266

Voltage: 277/480
 Amperage: 1203
 Kilowatts: 1000
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	2246.7	2247	2247.2	2247.5	2247.7	2247.8
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	482	482	481	481	480
PH2	482	481	482	481	482	482
PH3	483	482	482	483	482	483
Amperage PH1	0	1200	1199	1198	1199	0
PH2	0	1199	1201	1202	1202	0
PH3	0	1200	1200	1199	1199	0
Kilowatts	0	1000	1001	1000	1000	0
Oil Pressure	35	32	28	26	26	26
Oil Temperature						
Coolant Temperature	175°F	180°F	180°F	180°F	180°F	175°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28	28	28	28	28	28
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	22°F	22°F	23°F	23°F	23°F	23°F

Technician Signature: _____

Customer Signature: _____