



Customer: Central States Diesel Generators STK#2403

Address: 2001 S Prairie Ave.

City/ State/ Zip Waukesha, WI 53189

Contact: Patrick Paden

Phone: 262-995-7655

R#: 6682

Test Date 2-4-2019

Engine Make/ Model: Cummins LTA10G1

Engine Spec/ Serial: 34860950

Unit Make/ Model: Cummins 250DFAC

Unit Spec/ Serial: E970638481

Voltage: 277/480

Amperage: 301

Kilowatts: 250

Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	193.5	193.7	194	194.2	194.5	194.6
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	486	486	487	487	487	486
PH2	487	486	487	487	487	487
PH3	486	486	485	486	486	486
Amperage PH1	0	299	296	297	297	0
PH2	0	297	297	296	296	0
PH3	0	296	298	297	298	0
Kilowatts	0	250	250	250	250	0
Oil Pressure	40	35	34	34	34	35
Oil Temperature	201°F	220°F	223°F	224°F	224°F	200°F
Coolant Temperature	185°F	190°F	190°F	191°F	190°F	185°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28	28	28	28	28	28
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	45°F	46°F	46°F	46°F	46°F	46°F

Technician Signature: _____

Customer Signature: _____