



Customer: Central States Diesel Generators STK#2404

Address: 2001 S Prairie Ave.

City/ State/ Zip Waukesha, WI 53189

Contact: Patrick Paden

Phone: 262-995-7655

R#: 6706

Test Date 2-7-2019

Engine Make/ Model: Detroit Diesel Series 60

Engine Spec/ Serial: 06R093984

Unit Make/ Model: Detroit Diesel Spectrum 300DSED

Unit Spec/ Serial: 2117863

Voltage: 277/480

Amperage: 361

Kilowatts: 300

Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	483	483.2	483.5	483.7	484	484.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	481	480	480	481	481	481
PH2	482	482	481	481	482	482
PH3	481	480	480	481	480	481
Amperage PH1	0	360	361	362	361	0
PH2	0	360	362	360	361	0
PH3	0	361	360	361	360	0
Kilowatts	0	300	300	300	300	0
Oil Pressure	40	37	34	33	33	34
Oil Temperature						
Coolant Temperature	180°F	180°F	180°F	180°F	180°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.9	27.9	27.9	27.9	27.9	27.9
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	31°F	31°F	31°F	31°F	32°F	32°F

Technician Signature: \_\_\_\_\_

Customer Signature: \_\_\_\_\_