



Customer: Central States Diesel Generators STK#2405
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 8037
 Test Date 9-26-2019

Engine Make/ Model: Cummins QSK50-G4 NR2
 Engine Spec/ Serial: 33175916
 Unit Make/ Model: Cummins DQGAB-7371398
 Unit Spec/ Serial: S/N: K080221789 SPEC: A

Voltage: 277/480
 Amperage: 2255.3
 Kilowatts: 1500
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	159	159	159	160	160	160
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	485	485	486	485	485	485
PH2	485	485	485	485	485	485
PH3	486	485	486	486	485	486
Amperage PH1	0	1788	1787	1786	1789	0
PH2	0	1790	1784	1787	1786	0
PH3	0	1786	1785	1785	1789	0
Kilowatts	0	1500	1500	1500	1500	0
Oil Pressure	82	79	78	78	78	80
Oil Temperature						
Coolant Temperature	180°F	181°F	182°F	182°F	182°F	181°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	26.9	26.9	26.9	26.9	26.9	26.9
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	67°F	67°F	67°F	68°F	68°F	69°F

Technician Signature: Randy Pool

Customer Signature: _____