



Customer: Central States Diesel Generators STK#2406

Address: 2001 S Prairie Ave.

City/ State/ Zip Waukesha, WI 53189

Contact: Patrick Paden

Phone: 262-995-7655

R#: 6766

Test Date 2-25-2019

Engine Make/ Model: Cummins QSX15-G9

Engine Spec/ Serial: 79173075

Voltage: 277/480

Amperage: 602

Unit Make/ Model: Cummins DFEK-5763970

Kilowatts: 500

Unit Spec/ Serial: E060919018 Spec. F

Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	265	265.3	265.5	265.7	266	266.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	481	480	481	481	481	481
PH2	481	481	481	480	481	481
PH3	479	480	479	479	480	479
Amperage PH1	0	602	601	602	600	0
PH2	0	601	602	601	602	0
PH3	0	601	602	603	601	0
Kilowatts	0	500	500	500	500	0
Oil Pressure	42	39	37	37	37	39
Oil Temperature	210°F	223°F	223°F	223°F	223°F	210°F
Coolant Temperature	175°F	177°F	177°F	177°F	177°F	175°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.5	27.5	27.5	27.5	27.5	27.5
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	7°F	7°F	7°F	7°F	7°F	7°F

Technician Signature: _____

Customer Signature: _____