



Customer: Central States Diesel Generators STK#2416
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 7285
 Test Date 5-15-2019

Engine Make/ Model: 6068HF285
 Engine Spec/ Serial: PE6068L019340
 Unit Make/ Model: Katolight D150FPJ4T3
 Unit Spec/ Serial: 159132-0208

Voltage: 120/208
 Amperage: 417
 Kilowatts: 150
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	447	447	447	448	448	448
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	208	207	207	207	208	208
PH2	207	207	208	207	208	207
PH3	208	208	208	207	208	208
Amperage PH1	0	418	419	418	419	0
PH2	0	420	419	418	419	0
PH3	0	419	419	419	420	0
Kilowatts	0	150	151	150	151	0
Oil Pressure	50	48	46	45	45	47
Oil Temperature						
Coolant Temperature	178°F	180°F	180°F	180°F	180°F	179°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	13.7	13.7	13.7	13.7	13.7	13.7
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	69°F	69°F	70°F	70°F	70°F	71°F

Technician Signature: _____

Customer Signature: _____