



Customer: Central States Diesel Generators STK#2417
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 7580
 Test Date 7-10-2019

Engine Make/ Model: GM 8.1L
 Engine Spec/ Serial: 8270
 Unit Make/ Model: Katolight SEN80FPG4
 Unit Spec/ Serial: LM375615-97970-0404

Voltage: 120/208
 Amperage: 277
 Kilowatts: 80
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	109.6	109.8	110.1	110.3	110.6	110.7
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	208	208	208	208	208	208
PH2	209	209	210	209	209	209
PH3	208	209	208	208	209	208
Amperage PH1	0	163	100	75	71	0
PH2	0	165	98	73	70	0
PH3	0	162	102	76	72	0
Kilowatts	0	59	36	27	26	0
Oil Pressure	44	40	38	36	36	40
Oil Temperature						
Coolant Temperature	155°F	160°F	160°F	160°F	160°F	158°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	13.3	13.3	13.3	13.3	13.3	13.3
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	76°F	76°F	76°F	77°F	77°F	77°F

Technician Signature: Randy Pool

Customer Signature: Unable to obtain 100% load due to lack of fuel supply.