

Customer Name	Central States Diesel Generators	Date	4/12/2019		
Equipment Make	Cummins	Ambient Temp	50		
Equipment Model	600DFGB VTA28	kW	600	Voltage	480
Equipment Serial	J950591729	Unit Hours	541	Site	

Time	Avg Voltage	Avg Amperage	HZ	% Load	kW	Battery Voltage	Oil Pressure	Coolant Temp	Oil Temp
11:20	483	0	60	0	0	28	83	130	110
11:25	483	200	60	28	170	28	81	150	148
11:30	483	345	60	50	300	28	69	180	159
11:35	483	713	60	100	600	27.8	63	181	183
11:40	483	713	60	100	600	27.8	62	182	193
11:45	483	723	60	100	600	27.8	61	182	196
11:50	483	720	60	100	600	27.8	62	182	196
11:55	483	721	60	100	600	27.8	62	183	196
12:00	483	721	60	100	600	27.8	62	183	196
12:05	483	723	60	100	600	27.8	61	182	197
12:10	483	722	60	100	600	27.8	62	182	197
12:15	483	722	60	100	600	27.8	62	183	198
12:20	483	723	60	100	600	27.8	61	182	198
15min cooldown									
	482	0	60		0		70	175	179
Amps At	%=	Amps At	%=	Amps At	%=	Amps At	%=	Amps At	%=

NOTES:

Witness Signature	Date
Technician Signature Dale Routh	Date 4/12/2019