



Customer: Central States Diesel Generators STK#2421
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-995-7655

R#: 6759
 Test Date 2-22-2019

Engine Make/ Model: Cummins NTA-855-G3
 Engine Spec/ Serial: 30366427
 Unit Make/ Model: Cummins DFCC-4964251
 Unit Spec/ Serial: I010279468 Spec. V

Voltage: 120/208
 Amperage: 972
 Kilowatts: 350
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	509.2	509.4	509.7	509.9	510.2	510.3
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	209	209	208	208	209	209
PH2	209	209	208	209	209	209
PH3	209	209	208	209	209	209
Amperage PH1	0	970	972	968	968	0
PH2	0	968	971	968	968	0
PH3	0	970	972	969	968	0
Kilowatts	0	350	350	350	350	0
Oil Pressure	58	50	50	49	49	49
Oil Temperature	210°F	219°F	219°F	219°F	219°F	210°F
Coolant Temperature	175°F	180°F	180°F	180°F	180°F	175°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28.4	28.4	28.4	28.4	28.4	28.4
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	30°F	30°F	30 Min.	30°F	31°F	31°F

Technician Signature: Randy Pool

Customer Signature: _____