



Customer: Central States Diesel Generators STK#2432  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-995-7655

R#: 6775  
 Test Date 2-25-2019

Engine Make/ Model: John Deere 4039TF004  
 Engine Spec/ Serial: CD4039T299609  
 Unit Make/ Model: Kohler 60R0ZJ71  
 Unit Spec/ Serial: 382751

Voltage: 120/240  
 Amperage: 250  
 Kilowatts: 60  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	413.8	414	414.3	414.5	414.8	414.9
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	241	241	241	241	241	241
PH2	0	0	0	0	0	0
PH3	0	0	0	0	0	0
Amperage PH1	0	250	250	250	250	0
PH2	0	250	250	250	250	0
PH3	0	0	0	0	0	0
Kilowatts	0	60	60	60	60	0
Oil Pressure	50	46	45	45	45	46
Oil Temperature						
Coolant Temperature	180°F	188°F	188°F	188°F	188°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	15	15	15	15	15	15
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	8°F	8°F	8°F	8°F	8°F	8°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_