



Customer: Central States Diesel Generators #2434
 Address: 2001 S. Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847.997.8090

R#: 7009
 Test Date 2019.04.02

Engine Make/ Model: Cummins LTA10G1
 Engine Spec/ Serial: 34676255
 Unit Make/ Model: Cummins/ Onan 250DFAC
 Unit Spec/ Serial: J920489442 55759A

Voltage: 208
 Amperage: 868
 Kilowatts: 250
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	483.2	483.5	483.7	484	484.2	484.3
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	208	208	207	208	208	208
PH2	208	208	207	208	208	208
PH3	208	208	208	207	208	208
Amperage PH1	0	694	694	695	693	0
PH2	0	695	693	694	693	0
PH3	0	694	694	695	693	0
Kilowatts	0	250	250	250	250	0
Oil Pressure	44	41	38	35	35	37
Oil Temperature						
Coolant Temperature	180°F	185°F	185°F	185°F	185°F	183°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28	28	28	28	28	28
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	37°F	37°F	37°F	38°F	38°F	38°F

Technician Signature: Randy Pool

Customer Signature: _____