



Customer: Central States Diesel Generators STK#2436

Address: 2001 S Prairie Ave.

City/ State/ Zip Waukesha, WI 53189

Contact: Patrick Paden

Phone: 262-995-7655

R#: 6895

Test Date 3-19-2019

Engine Make/ Model: Caterpillar C15

Engine Spec/ Serial: FSE00454

Unit Make/ Model: Caterpillar C15

Unit Spec/ Serial: FSE00454

Voltage: 277/480

Amperage: 601

Kilowatts: 500

Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	1671.9	1672.1	1672.4	1672.6	1672.9	1673
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	480	480	480	480
PH2	480	480	480	480	480	480
PH3	479	479	479	479	479	479
Amperage PH1	0	601	603	602	601	0
PH2	0	602	601	602	601	0
PH3	0	603	602	603	604	0
Kilowatts	0	500	500	500	500	0
Oil Pressure	74	70	69	69	69	71
Oil Temperature						
Coolant Temperature	180°F	194°F	195°F	195°F	196°F	185°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27	27	27	27	27	27
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	39°F	39°F	39°F	39°F	39°F	40°F

Technician Signature: \_\_\_\_\_

Customer Signature: \_\_\_\_\_