



Customer: Central States Diesel Generators STK#2437
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 7010
 Test Date 4-9-2019

Engine Make/ Model: Cummins KTA19G3
 Engine Spec/ Serial: 37143679
 Unit Make/ Model: Cummins ONAN 450DFEC
 Unit Spec/ Serial: G920477981

Voltage: 277/480
 Amperage: 542
 Kilowatts: 450
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	1094.9	1095.1	1095.4	1095.6	1095.9	1096
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	479	478	478	479	480
PH2	483	482	482	483	482	483
PH3	479	478	478	477	478	479
Amperage PH1	0	542	543	542	542	0
PH2	0	541	542	543	543	0
PH3	0	543	543	543	542	0
Kilowatts	0	450	450	450	450	0
Oil Pressure	95	80	78	78	77	80
Oil Temperature						
Coolant Temperature	180°F	185°F	185°F	185°F	185°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.8	27.8	27.8	27.8	27.8	27.8
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	58°F	58°F	58°F	58°F	57°F	57°F

Technician Signature: Randy Pool

Customer Signature: _____