

# Work Order

		✖
WO No.: 6943		Open / History: H
WO Date: 03/21/2019		Job Status: Completed
Sched. Date: 03/28/2019		Status Change Date: 2019.04.04 (INV)
Completed Date: 04/10/2019		Assign To Type: Technician
Bill With Work Order:		Assign To: (RANDY POOL)
Follow Up From WO#: 0		
Customer P.O. No.:		Asset ID: CU-37204785
CEES Quote:		Unit #: 2446
		Engine Make: CUMMINS
Site: CENTRAL STATES DIESEL GENERATORS		Engine Model No.: KTA19G4
Site_addr: 2001 S. PRAIRIE AVE.		Engine Serial No.: 37204785
City: WAUKESHA		Engine Spec:
State: WISCONSIN		Unit Make: CUMMINS/ ONAN
Zip: 53189		Unit Model No.: DFED-5567870
Requested By: PATRICK PADEN		Unit Serial No.: 1020412633
Req. Telephone:		Unit Spec: G
Req. E-mail:		Engine Hours: 70
Bill To: (Invoice): CENTRAL STATES DIESEL GENERATORS		
Account #: 1121		Round Trip Miles: 0
Perform For Type: Customer		Tolls Paid: 0
Perform For: CENTRAL STATES DIESEL GENERATORS (CENTRAL STATES DIESEL GENERATORS)		
		Time In: 03/28/2019 06:51:00 PM
WO Type: Load Bank		Time Out: 03/28/2019 06:51:00 PM
Problem Type: INSPECT AND LOAD BANK FOR SALE		
Brief Description: INSPECT AND LOAD BANK FOR SALE		Signed Signature:
		Kilowatts:
		Voltage:
Customer Complaint: PERFORM INSPECTION PERFORM 1-HOUR LOAD-BANK TEST PERFORM PM SERVICES REPLACE ENGINE THERMOSTATS.		Cable Run (ft): 0
Work Performed: 3-28-19 (RANDY) CONNECTED FUEL, BATTERIES, AND LOAD BANK. BEGAN LOAD TEST, ENGINE OVERHEATS 5 MINUTES INTO LOAD BANK TEST. THERMOSTATS ARE DEFECTIVE. DRAINED COOLING SYSTEM AND REMOVED AND REPLACED 2 ENGINE THERMOSTATS AND SEALS. ENGINE NOW COOLS PROPERLY. NEED TO PERFORM PM SERVICES. NEED TO DO CSDG VIDEO. 3-29-19 (RANDY) PERFORMED PM SERVICE. CHANGED LUBE OIL AND FILTERS. ALL PARTS PROVIDED BY CSDG. 4-2-19 (RANDY) RAN LOAD TEST FOR CSDG VIDEO.		
Follow-Ups:		



Customer: Central States Diesel Generators STK#2446  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 847-997-8090

R#: 6943  
 Test Date 3-28-2019

Engine Make/ Model: Cummins KTA19G4  
 Engine Spec/ Serial: 37204785  
 Unit Make/ Model: Cummins DFED-5567870  
 Unit Spec/ Serial: Spec. G S/N I020412633

Voltage: 277/480  
 Amperage: 601  
 Kilowatts: 500  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	69	69.3	69.5	69.8	70	70.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	480	481	480	480
PH2	478	479	478	478	479	478
PH3	482	482	481	482	482	482
Amperage PH1	0	602	603	602	602	0
PH2	0	601	602	601	601	0
PH3	0	603	602	601	602	0
Kilowatts	0	500	500	500	500	0
Oil Pressure	95	80	70	68	66	70
Oil Temperature	185°F	192°F	192°F	193°F	193°F	187°F
Coolant Temperature	180°F	188°F	188°F	189°F	189°F	183°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.8	27.8	27.8	27.8	27.8	27.8
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	57°F	57°F	57°F	57°F	57°F	57°F

Technician Signature: \_\_\_\_\_

Customer Signature: \_\_\_\_\_


# Sales Order

04/10/2019

## Charles Equipment

Charles Equipment Energy Systems, LLC  
530 Santa Rosa Drive  
Des Plaines, IL 60018  
Phone: (630) 834-6000  
Fax: (630) 543-4174  
Email: cees@charlesequipment.com

6943



### Bill To:

CENTRAL STATES DIESEL GENERATOR  
2001 S. PRAIRIE AVE  
WAUKESHA, WI 53189

Customer: CENTRAL STATES DIESEL GENERATOR

### Ship To:

CENTRAL STATES DIESEL GENERATOR  
2001 S. PRAIRIE AVE  
WAUKESHA, WI 53189

Contact: CENTRAL STATES DIESEL GENERATO  
PO Number: UNIT# 2446

### Notes

PERFORMED INSPECTION, LOADBANK TEST, PM SERVICES, AND VIDEO - RAN UNIT LOAD TEST

Seller	Payment Terms	FOB Point	Carrier	Ship Service	Requested Ship Date
debbs	Net 10	Origin	Will Call		03/31/2019

Item #	Type	Number / Description	Unit Price	Qty Ordered	Total Price
1	Sale	SFT/M/WI - STRAIGHT FIELD LABOR - WI	\$ 110.00	16 hr	\$ 1,760.00

This invoice is based on CEES standard conditions of sale, whether attached hereto or not, a copy of which is on file at the CEES corporate office. CEES hereby objects to any additional or different terms set forth in any request for quotation, specification, purchase order or any other document of purchaser or provided by purchaser. Acceptance of additional or different terms must be specifically agreed to in writing by CEES. All credit card payments will be charged a 3% administration fee.

**Subtotal:** \$ 1,760.00  
**Sales Tax:** \$ 0.00  
**Total:** \$ 1,760.00

# Work Order

		✕
WO No.: 7007		Open / History: H
WO Date: 03/29/2019		Job Status: Completed
Sched. Date: 04/03/2019		Status Change Date: 2019.04.04 (INV)
Completed Date: 04/10/2019		Assign To Type: Technician
Bill With Work Order:		Assign To: (RANDY POOL)
Follow Up From WO#: 0		
Customer P.O. No.:		Asset ID: CA-3FZ03053
CEES Quote:		Unit #: 2452
		Engine Make: CATERPILLAR
Site: CENTRAL STATES DIESEL GENERATORS		Engine Model No.: 3412
Site_addr: 2001 S. PRAIRIE AVE.		Engine Serial No.: 3FZ03053
City: WAUKESHA		Engine Spec:
State: WISCONSIN		Unit Make: CATERPILLAR
Zip: 53189		Unit Model No.: 3412
Requested By: PATRICK PADEN		Unit Serial No.: 9EP01555
Req. Telephone:		Unit Spec:
Req. E-mail:		Engine Hours: 263
Bill To: (Invoice): CENTRAL STATES DIESEL GENERATORS		
Account #: 1121		Round Trip Miles: 0
Perform For Type: Customer		Tolls Paid: 0
Perform For: CENTRAL STATES DIESEL GENERATORS (CENTRAL STATES DIESEL GENERATORS)		
		Time In: 04/03/2019 10:53:00 AM
WO Type: Load Bank		Time Out: 04/03/2019 10:53:00 AM
Problem Type: INSPECT AND LOAD BANK FOR SALE		
Brief Description: INSPECT AND LOAD BANK FOR SALE		Signed Signature:
		Kilowatts: 500
Customer Complaint: PERFORM INSPECTION PERFORM 1-HOUR LOAD-BANK TEST		Voltage: 277/480
		Cable Run (ft): 0
Work Performed: 4-2-19 (RANDY) PERFORMED INSPECTION AND CONNECTED FUEL AND LOAD BANK. RAN GENERATOR TO CONFIRM PROPER OPERATION. NOTE: VIDEO TEST TO BE DONE 4-3-19. 4-3-19 (RANDY) PERFORMED 1 HOUR LOAD BANK TEST. VIDEO DONE.		
Follow-Ups:		



Customer: Central States Diesel Generators STK#2452  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 847-997-8090

R#: 7007  
 Test Date 4-3-2019

Engine Make/ Model: Caterpillar 3412  
 Engine Spec/ Serial: 3FZ03053  
 Unit Make/ Model: Caterpillar 3412  
 Unit Spec/ Serial: 9EP015555

Voltage: 277/480  
 Amperage: 601  
 Kilowatts: 500  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	262	262	262	262	263	263
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	481	481	481	481	481	481
PH2	480	480	480	480	480	480
PH3	480	480	480	480	480	480
Amperage PH1	0	602	603	602	601	0
PH2	0	600	601	601	601	0
PH3	0	603	602	601	602	0
Kilowatts	0	500	500	500	500	0
Oil Pressure	82	74	73	73	73	75
Oil Temperature	190°F	207°F	207°F	208°F	207°F	192°F
Coolant Temperature	180°F	187°F	188°F	187°F	187°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27	27	27	27	27	27
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	44°F	44°F	44°F	45°F	45°F	45°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_


# Sales Order

04/10/2019

## Charles Equipment

Charles Equipment Energy Systems, LLC  
530 Santa Rosa Drive  
Des Plaines, IL 60018  
Phone: (630) 834-6000  
Fax: (630) 543-4174  
Email: cees@charlesequipment.com

7007



### Bill To:

CENTRAL STATES DIESEL GENERATOR  
2001 S. PRAIRIE AVE  
WAUKESHA, WI 53189

Customer: CENTRAL STATES DIESEL GENERATOR

### Ship To:

CENTRAL STATES DIESEL GENERATOR  
2001 S. PRAIRIE AVE  
WAUKESHA, WI 53189

Contact: CENTRAL STATES DIESEL GENERATO  
PO Number: UNIT# 2452

### Notes

PERFORMED INSPECTION, LOADBANK, PERFORMED VIDEO.


Seller	Payment Terms	FOB Point	Carrier	Ship Service	Requested Ship Date
debbs	Net 10	Origin	Will Call		04/10/2019

Item #	Type	Number / Description	Unit Price	Qty Ordered	Total Price
1	Sale	SFT/M/WI - STRAIGHT FIELD LABOR - WI	\$ 110.00	6 hr	\$ 660.00

This invoice is based on CEES standard conditions of sale, whether attached hereto or not, a copy of which is on file at the CEES corporate office. CEES hereby objects to any additional or different terms set forth in any request for quotation, specification, purchase order or any other document of purchaser or provided by purchaser. Acceptance of additional or different terms must be specifically agreed to in writing by CEES. All credit card payments will be charged a 3% administration fee.

**Subtotal:** \$ 660.00  
**Sales Tax:** \$ 0.00  
**Total:** \$ 660.00

# Work Order

			
WO No.:	7009	Open / History:	H
WO Date:	03/29/2019	Job Status:	Completed
Sched. Date:	04/02/2019	Status Change Date:	2019.04.03 (INV)
Completed Date:	04/10/2019	Assign To Type:	Technician
Bill With Work Order:		Assign To:	(RANDY POOL)
Follow Up From WO#:	0		
Customer P.O. No.:		Asset ID:	CU-34766255
CEES Quote:		Unit #:	2434
		Engine Make:	CUMMINS
Site:	CENTRAL STATES DIESEL GENERATORS	Engine Model No.:	LTA10G1
Site_addr:	2001 PRAIRIE AVE.	Engine Serial No.:	34766255
City:	WAUKESHA	Engine Spec:	
State:	WISCONSIN	Unit Make:	CUMMINS/ ONAN
Zip:	53189	Unit Model No.:	250DFAC
Requested By:	PATRICK PADEN	Unit Serial No.:	J920489442
Req. Telephone:		Unit Spec:	55759A
Req. E-mail:		Engine Hours:	0
Bill To: (Invoice):	CENTRAL STATES DIESEL GENERATORS		
Account #:	1121	Round Trip Miles:	0
Perform For Type:	Customer	Tolls Paid:	0
Perform For:	CENTRAL STATES DIESEL GENERATORS (CENTRAL STATES DIESEL GENERATORS)		
		Time In:	04/02/2019 11:37:00 AM
WO Type:	Load Bank	Time Out:	04/02/2019 11:37:00 AM
Problem Type:	INSPECT AND LOAD BANK FOR SALE		
Brief Description:	INSPECT AND LOAD BANK FOR SALE	Signed Signature:	
		Kilowatts:	250
Customer Complaint:	PERFORM INSPECTION PERFORM 1-HOUR LOAD-BANK TEST	Voltage:	120/208
		Cable Run (ft):	0
Work Performed:	4-2-19 (RANDY) PERFORMED INSPECTION AND 1-HOUR LOAD-BANK TEST		
Follow-Ups:			



Customer: Central States Diesel Generators #2434  
 Address: 2001 S. Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 847.997.8090

R#: 7009  
 Test Date 2019.04.02

Engine Make/ Model: Cummins LTA10G1  
 Engine Spec/ Serial: 34676255  
 Unit Make/ Model: Cummins/ Onan 250DFAC  
 Unit Spec/ Serial: J920489442 55759A

Voltage: 208  
 Amperage: 868  
 Kilowatts: 250  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	483.2	483.5	483.7	484	484.2	484.3
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	208	208	207	208	208	208
PH2	208	208	207	208	208	208
PH3	208	208	208	207	208	208
Amperage PH1	0	694	694	695	693	0
PH2	0	695	693	694	693	0
PH3	0	694	694	695	693	0
Kilowatts	0	250	250	250	250	0
Oil Pressure	44	41	38	35	35	37
Oil Temperature						
Coolant Temperature	180°F	185°F	185°F	185°F	185°F	183°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28	28	28	28	28	28
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	37°F	37°F	37°F	38°F	38°F	38°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_




# Estimate

04/10/2019

## Charles Equipment

Charles Equipment Energy Systems, LLC  
530 Santa Rosa Drive  
Des Plaines, IL 60018  
Phone: (630) 834-6000  
Fax: (630) 543-4174  
Email: cees@charlesequipment.com

7009



### Bill To:

CENTRAL STATES DIESEL GENERATOR  
2001 S. PRAIRIE AVE  
WAUKESHA, WI 53189

Customer: CENTRAL STATES DIESEL GENERATOR

### Ship To:

CENTRAL STATES DIESEL GENERATOR  
2001 S. PRAIRIE AVE  
WAUKESHA, WI 53189

Contact: CENTRAL STATES DIESEL GENERATO  
PO Number: UNIT# 2434

### Notes

PERFORMED INSPECTION AND LOADBANK TEST

Seller	Payment Terms	FOB Point	Carrier	Ship Service	Requested Ship Date
debbs	Net 10	Origin	Will Call		04/10/2019

Item #	Type	Number / Description	Unit Price	Qty Ordered	Total Price
1	Sale	SFT/M/WI - STRAIGHT FIELD LABOR - WI	\$ 110.00	2.5 hr	\$ 275.00

This invoice is based on CEES standard conditions of sale, whether attached hereto or not, a copy of which is on file at the CEES corporate office. CEES hereby objects to any additional or different terms set forth in any request for quotation, specification, purchase order or any other document of purchaser or provided by purchaser. Acceptance of additional or different terms must be specifically agreed to in writing by CEES. All credit card payments will be charged a 3% administration fee.

**Subtotal:** \$ 275.00  
**Sales Tax:** \$ 0.00  
**Total:** \$ 275.00

# Work Order

		<input checked="" type="checkbox"/>	
WO No.:	7011	Open / History:	H
WO Date:	03/29/2019	Job Status:	Completed
Sched. Date:	04/04/2019	Status Change Date:	2019.04.04 (INV)
Completed Date:	04/10/2019	Assign To Type:	Technician
Bill With Work Order:		Assign To:	(RANDY POOL)
Follow Up From WO#:	0		
Customer P.O. No.:		Asset ID:	IH-1833330C1
CEES Quote:		Unit #:	2438
		Engine Make:	INTERNATIONAL HARVESTER
Site:	CENTRAL STATES DIESEL GENERATORS	Engine Model No.:	GCD325
Site_addr:	2001 S. PRAIRIE AVE.	Engine Serial No.:	1833330C1
City:	WAUKESHA	Engine Spec:	
State:	WISCONSIN	Unit Make:	OLYMPIAN
Zip:	53189	Unit Model No.:	D200P4
Requested By:	PATRICK PADEN	Unit Serial No.:	E6028B/001
Req. Telephone:		Unit Spec:	
Req. E-mail:		Engine Hours:	0
Bill To: (Invoice):	CENTRAL STATES DIESEL GENERATORS		
Account #:	1121	Round Trip Miles:	0
Perform For Type:	Customer	Tolls Paid:	0
Perform For:	CENTRAL STATES DIESEL GENERATORS (CENTRAL STATES DIESEL GENERATORS)		
		Time In:	04/04/2019 03:34:00 PM
WO Type:	Load Bank	Time Out:	04/04/2019 03:34:00 PM
Problem Type:	INSPECT AND LOAD BANK FOR SALE		
Brief Description:	INSPECT AND LOAD BANK FOR SALE	Signed Signature:	
Customer Complaint:	PERFORM INSPECTION PERFORM 1-HOUR LOAD-BANK TEST	Kilowatts:	200
Work Performed:	4-4-19 (RANDY) PERFORMED INSPECTION AND 1-HOUR LOAD-BANK TEST	Voltage:	480
		Cable Run (ft):	0
Follow-Ups:			



Customer: Central States Diesel Generators STK#2438  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 847-997-8090

R#: 7011  
 Test Date 4-4-2019

Engine Make/ Model: International GCD325  
 Engine Spec/ Serial: 1833330C1  
 Unit Make/ Model: Olympian D200P4  
 Unit Spec/ Serial: E6028B/001

Voltage: 277/480  
 Amperage: 241  
 Kilowatts: 200  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	2129.3	2129.5	2129.8	2130	2130.3	2130.4
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	481	481	481	481	481	481
PH2	480	480	480	480	480	480
PH3	480	481	481	481	481	481
Amperage PH1	0	241	240	241	241	0
PH2	0	240	242	241	242	0
PH3	0	241	241	240	240	0
Kilowatts	0	200	200	200	200	0
Oil Pressure	65	61	60	60	60	62
Oil Temperature						
Coolant Temperature	185°F	190°F	190°F	190°F	190°F	185°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28	28	28	28	28	28
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	38°F	38°F	38°F	38°F	37°F	37°F

Technician Signature: \_\_\_\_\_

Customer Signature: \_\_\_\_\_


# Sales Order

04/10/2019

## Charles Equipment

Charles Equipment Energy Systems, LLC  
530 Santa Rosa Drive  
Des Plaines, IL 60018  
Phone: (630) 834-6000  
Fax: (630) 543-4174  
Email: cees@charlesequipment.com

7011



### Bill To:

CENTRAL STATES DIESEL GENERATOR  
2001 S. PRAIRIE AVE  
WAUKESHA, WI 53189

Customer: CENTRAL STATES DIESEL GENERATOR

### Ship To:

CENTRAL STATES DIESEL GENERATOR  
2001 S. PRAIRIE AVE  
WAUKESHA, WI 53189

Contact: CENTRAL STATES DIESEL GENERATO  
PO Number: UNIT# 2438

### Notes

PERFORMED INSPECTION AND LOADBANK TEST

Seller	Payment Terms	FOB Point	Carrier	Ship Service	Requested Ship Date
debbs	Net 10	Origin	Will Call		04/10/2019

Item #	Type	Number / Description	Unit Price	Qty Ordered	Total Price
1	Sale	SFT/M/WI - STRAIGHT FIELD LABOR - WI	\$ 110.00	2.5 hr	\$ 275.00
2	Sale	OT/F/WI - NORMAL OVERTIME FIELD - WI	\$ 135.00	1 hr	\$ 135.00

This invoice is based on CEES standard conditions of sale, whether attached hereto or not, a copy of which is on file at the CEES corporate office. CEES hereby objects to any additional or different terms set forth in any request for quotation, specification, purchase order or any other document of purchaser or provided by purchaser. Acceptance of additional or different terms must be specifically agreed to in writing by CEES. All credit card payments will be charged a 3% administration fee.

**Subtotal:** \$ 410.00  
**Sales Tax:** \$ 0.00  
**Total:** \$ 410.00