



Customer: Central States Diesel Generators STK#2439
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 7314
 Test Date 5-23-2019

Engine Make/ Model: Cummins QSK50-G4
 Engine Spec/ Serial: 33176726
 Unit Make/ Model: Cummins DQGAB-7567688
 Unit Spec/ Serial: Spec.A A090228686

Voltage: 277/480
 Amperage: 1805
 Kilowatts: 1500
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	199	199	199	200	200	200
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	480	480	480	480
PH2	480	480	480	480	480	480
PH3	480	480	480	480	480	480
Amperage PH1	0	1805	1806	1805	1807	0
PH2	0	1807	1805	1806	1806	0
PH3	0	1806	1807	1807	1806	0
Kilowatts	0	1500	1500	1500	1500	0
Oil Pressure	85	78	77	77	77	79
Oil Temperature	200°F	205°F	205°F	205°F	205°F	200°F
Coolant Temperature	174°F	175°F	175°F	176°F	176°F	174°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	26.9	26.9	26.9	26.9	26.9	26.9
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	71°F	71°F	71°F	72°F	72°F	72°F

Technician Signature: _____

Customer Signature: _____