



Customer: Central States Diesel Generators STK#2441
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 7313
 Test Date 6/4/2019

Engine Make/ Model: QSK78-G10
 Engine Spec/ Serial: 66301943
 Unit Make/ Model: DQLE-8030839
 Unit Spec/ Serial: L110286748

Voltage: 277/480
 Amperage: 3007
 Kilowatts: 2500
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	111.1	111.3	111.6	111.8	112.1	112.2
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	480	480	480	480
PH2	481	481	481	481	481	481
PH3	479	479	479	479	479	479
Amperage PH1	0	3011	3013	3012	3011	0
PH2	0	3010	3010	3011	3009	0
PH3	0	3009	3009	3010	3011	0
Kilowatts	0	2500	2500	2500	2500	0
Oil Pressure	85	74	72	72	72	75
Oil Temperature	180°F	186°F	187°F	187°F	187°F	182°F
Coolant Temperature	195°F	214°F	213°F	214°F	214°F	200°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	26.5	26.5	26.5	26.5	26.5	26.5
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	64°F	64°F	65°F	65°F	65°F	66°F

Technician Signature: _____

Customer Signature: _____