



Customer: Central States Diesel Generators STK#2442
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 7126
 Test Date 4/24/2019

Engine Make/ Model: Cummins KTTA50-G2
 Engine Spec/ Serial: 33145037
 Unit Make/ Model: Cummins ONAN DFMB-3387060
 Unit Spec/ Serial: A000051968

Voltage: 277/480
 Amperage: 1804
 Kilowatts: 1500
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	122.9	123.1	123.4	123.6	123.9	124
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	482	482	482	482	483	482
PH2	483	483	483	483	482	483
PH3	483	482	482	482	482	483
Amperage PH1	0	1803	1801	1803	1802	0
PH2	0	1804	1801	1801	1804	0
PH3	0	1803	1802	1801	1802	0
Kilowatts	0	1505	1503	1503	1504	0
Oil Pressure	81	70	68	67	67	77
Oil Temperature	190°F	210°F	211°F	210°F	211°F	191°F
Coolant Temperature	183°F	186°F	187°F	187°F	187°F	184°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.9	27.9	27.9	27.9	27.9	27.9
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	50°F	50°F	50°F	51°F	51°F	51°F

Technician Signature: _____

Customer Signature: _____