



Customer: Central States Diesel Generators STK#2443
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 7250
 Test Date 5-3-2019

Engine Make/ Model: Cummins QST30-G5
 Engine Spec/ Serial: 37192804
 Unit Make/ Model: Cummins DFHD-4479532
 Unit Spec/ Serial: E000108795

Voltage: 277/480
 Amperage: 1504
 Kilowatts: 1000
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	473.1	473.4	473.6	473.9	474.1	474.2
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	480	480	480	480
PH2	480	480	480	480	480	480
PH3	481	480	481	481	480	481
Amperage PH1	0	1204	1204	1205	1203	0
PH2	0	1203	1204	1203	1204	0
PH3	0	1204	1205	1204	1204	0
Kilowatts	0	1000	1001	1000	1000	0
Oil Pressure	62	48	48	47	47	56
Oil Temperature	180°F	199°F	199°F	200°F	199°F	182°F
Coolant Temperature	174°F	175°F	175°F	175°F	175°F	174°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.1	27.1	27.1	27.1	27.1	27.1
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	52°F	52°F	52°F	53°F	53°F	53°F

Technician Signature: Randy Pool

Customer Signature: _____