



Customer: Central States Diesel Generators STK#2446  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 847-997-8090

R#: 6943  
 Test Date 3-28-2019

Engine Make/ Model: Cummins KTA19G4  
 Engine Spec/ Serial: 37204785  
 Unit Make/ Model: Cummins DFED-5567870  
 Unit Spec/ Serial: Spec. G S/N I020412633

Voltage: 277/480  
 Amperage: 601  
 Kilowatts: 500  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	69	69.3	69.5	69.8	70	70.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	480	481	480	480
PH2	478	479	478	478	479	478
PH3	482	482	481	482	482	482
Amperage PH1	0	602	603	602	602	0
PH2	0	601	602	601	601	0
PH3	0	603	602	601	602	0
Kilowatts	0	500	500	500	500	0
Oil Pressure	95	80	70	68	66	70
Oil Temperature	185°F	192°F	192°F	193°F	193°F	187°F
Coolant Temperature	180°F	188°F	188°F	189°F	189°F	183°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.8	27.8	27.8	27.8	27.8	27.8
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	57°F	57°F	57°F	57°F	57°F	57°F

Technician Signature: \_\_\_\_\_

Customer Signature: \_\_\_\_\_