



Customer: Central States Diesel Generators STK#2447
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 7284
 Test Date 5-15-2019

Engine Make/ Model: Caterpillar 3512 DITA
 Engine Spec/ Serial: 24Z09225
 Unit Make/ Model: Caterpillar 3512 DITA
 Unit Spec/ Serial: 24Z09225

Voltage: 277/480
 Amperage: 1504
 Kilowatts: 1250
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	370	370	370	371	371	371
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	485	484	485	485	485	485
PH2	483	483	483	483	484	483
PH3	484	485	484	484	484	484
Amperage PH1	0	1496	1493	1496	1495	0
PH2	0	1498	1496	1498	1493	0
PH3	0	1497	1496	1495	1493	0
Kilowatts	0	1253	1252	1253	1252	0
Oil Pressure	78	70	67	67	66	70
Oil Temperature						
Coolant Temperature	180°F	183°F	184°F	184°F	184°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	26	26	26	26	26	26
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	63°F	63°F	63°F	64°F	64°F	65°F

Technician Signature: _____

Customer Signature: _____