



Customer: Central States Diesel Generators STK#2450
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 6944
 Test Date 2019-03-22

Engine Make/ Model: John Deere 6068TF250
 Engine Spec/ Serial: PE6068T575599
 Unit Make/ Model: Kohler 125RE0ZJB
 Unit Spec/ Serial: Spec. GM31029-GA7 S/N 2104515

Voltage: 277/480
 Amperage: 151
 Kilowatts: 125
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	285.9	286.1	286.4	286.6	286.9	287
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	481	481	481	481	481	481
PH2	482	482	481	482	482	482
PH3	481	481	481	481	481	481
Amperage PH1	0	150	150	149	150	0
PH2	0	149	149	150	149	0
PH3	0	150	150	150	150	0
Kilowatts	0	125	125	125	125	0
Oil Pressure	55	47	45	40	40	47
Oil Temperature						
Coolant Temperature	175°F	180°F	180°F	180°F	180°F	175°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14.3	14.3	14.3	14.3	14.3	14.3
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	39°F	39°F	39°F	40°F	40°F	40°F

Technician Signature: _____

Customer Signature: _____