



Customer: Central States Diesel Generators STK#2452
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 7007
 Test Date 4-3-2019

Engine Make/ Model: Caterpillar 3412
 Engine Spec/ Serial: 3FZ03053
 Unit Make/ Model: Caterpillar 3412
 Unit Spec/ Serial: 9EP015555

Voltage: 277/480
 Amperage: 601
 Kilowatts: 500
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	262	262	262	262	263	263
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	481	481	481	481	481	481
PH2	480	480	480	480	480	480
PH3	480	480	480	480	480	480
Amperage PH1	0	602	603	602	601	0
PH2	0	600	601	601	601	0
PH3	0	603	602	601	602	0
Kilowatts	0	500	500	500	500	0
Oil Pressure	82	74	73	73	73	75
Oil Temperature	190°F	207°F	207°F	208°F	207°F	192°F
Coolant Temperature	180°F	187°F	188°F	187°F	187°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27	27	27	27	27	27
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	44°F	44°F	44°F	45°F	45°F	45°F

Technician Signature: Randy Pool

Customer Signature: _____