



Customer: Central States Diesel Generators STK#2454
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 7046
 Test Date 4-9-2019

Engine Make/ Model: Cummins QSX15-G9
 Engine Spec/ Serial: 79244379
 Unit Make/ Model: DEFH-5856374
 Unit Spec/ Serial: D070051069

Voltage: 277/480
 Amperage: 481
 Kilowatts: 400
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	235.2	235.4	235.7	235.9	236.2	236.3
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	480	480	480	480
PH2	481	482	482	481	481	481
PH3	480	481	481	480	481	480
Amperage PH1	0	480	481	481	481	0
PH2	0	481	480	480	481	0
PH3	0	480	481	482	480	0
Kilowatts	0	400	400	400	400	0
Oil Pressure	41	39	38	38	38	39
Oil Temperature	198°F	226°F	225°F	226°F	226°F	202°F
Coolant Temperature	179°F	180°F	180°F	180°F	180°F	179°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28	28	28	28	28	28
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	46°F	46°F	46°F	46°F	47°F	47°F

Technician Signature: Randy Pool

Customer Signature: _____